



4/5/2004

Ms. S Witkowski
Snap-N-Strut Ltd
4115 Hwy 51 N
Janesville WI 53545

Our Reference: File E218244
Your Reference: S WITKOWSKI
Subject: Preliminary Evaluation

Dear Ms. Witkowski:

We have completed our preliminary evaluation of your product and have the following comments.

For the record we are investigating the above subject product, using requirements from our standard for Hardware for the Support of Conduit, Tubing, and Cable, UL 2239. Please note that all paragraphs referenced below are from this Standard.

The constructions submitted are identical to the constructions currently covered in File E218244. This investigation is for the construction type 30-34 and smaller. These samples are being submitted to our Northbrook office for testing to the requirements for Smoke and Heat Release as described in Section 6.9.

MARKINGS

Provided that the tested constructions comply with the applicable requirements of the Standard, the following marking may be applied on the smallest unit carton or installation instructions:

"Suitable for use in Air Handling Spaces in accordance with Section 300.22 (C) and (D) of the National Electrical Code, and Rules 12-010 (3), (4), and (5), and 12-020 of the Canadian Electrical Code, Part 1" or an equivalent wording.

Please advise how you intend to provide these markings.

If you have any questions, please do not hesitate to contact us.

Sincerely,

Reviewed by:

Bryan L. Tatum
Senior Project Engineer
Department: 3015ERTP
Tel: 919-549-1939
Fax: 919-316-5624
E-mail: bryan.l.tatum@us.ul.com

Vincent L Quiett
Staff Engineer
Department: 3015ERTP
E-mail: vincent.l.quiett@us.ul.com

